

The Bays- Sampling and Discharge Summary- March

| Discharge Date | Site/WTP | pH | Turbidity/TSS | Oil and Grease |
|----------------|----------|----------|---------------------|----------------|
| | | Probe | Probe (correlation) | Visual |
| | | pH units | NTU | Y/N |
| | | 6.5-8.5 | 18 | Not visible |
| 1/03/2023 | C-WTP | 6.69 | 7.4 | N |
| 2/03/2023 | C-WTP | 6.64 | 8 | N |
| 6/03/2023 | C-WTP | 6.52 | 5 | N |
| 7/03/2023 | C-WTP | 6.75 | 1.4 | N |
| 8/03/2023 | C-WTP | 6.63 | 1.4 | N |
| 9/03/2023 | C-WTP | 6.94 | 1.4 | N |
| 10/03/2023 | C-WTP | 6.9 | 2.1 | N |
| 11/03/2023 | C-WTP | 7.01 | 3 | N |
| 12/03/2023 | C-WTP | 7.13 | 3.5 | N |
| 13/03/2023 | C-WTP | 6.7 | 4.5 | N |
| 14/03/2023 | C-WTP | 6.83 | 5.3 | N |
| 15/03/2023 | C-WTP | 6.99 | 6 | N |
| 16/03/2023 | C-WTP | 6.97 | 7.6 | N |
| 17/03/2023 | C-WTP | 6.79 | 8.1 | N |
| 18/03/2023 | C-WTP | 6.61 | 5 | N |
| 19/03/2023 | C-WTP | 6.75 | 5 | N |
| 20/03/2023 | C-WTP | 6.7 | 3.4 | N |
| 21/03/2023 | C-WTP | 6.7 | 11.5 | N |
| 22/03/2023 | C-WTP | 6.64 | 16.5 | N |
| 23/03/2023 | C-WTP | 6.78 | 5 | N |
| 24/03/2023 | C-WTP | 7.13 | 8.7 | N |
| 25/03/2023 | C-WTP | 6.85 | 1.4 | N |
| 26/03/2023 | C-WTP | 7.02 | 1.4 | N |
| 27/03/2023 | C-WTP | 6.67 | 1.4 | N |
| 28/03/2023 | C-WTP | 6.88 | 1.4 | N |
| 30/03/2023 | C-WTP | 6.86 | 1.4 | N |

PCY- Sampling and Discharge Summary- March

| Discharge Date | Site | pH | Turbidity/TSS | Oil and Grease |
|----------------|------|----------|---------------|----------------|
| | | Probe | Probe | Visual |
| | | pH units | NTU | Y/N |
| 1/03/2023 | PCY | 7.98 | 1.6 | N |
| 30/03/2023 | PCY | 8.32 | 48.8 | N |