

The Bays- WTP Discharge Summary- February 2024

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	18	Not visible
1/02/2024	C-WTP	6.9	1	N
2/02/2024	C-WTP	6.8	0.9	N
3/02/2024	C-WTP	6.9	0.9	N
4/02/2024	C-WTP	6.8	0.9	N
5/02/2024	C-WTP	6.8	1.2	N
6/02/2024	C-WTP	6.9	1	N
7/02/2024	C-WTP	6.9	0.9	N
8/02/2024	C-WTP	6.9	0.9	N
9/02/2024	C-WTP	7	1	N
10/02/2024	C-WTP	7	1.2	N
11/02/2024	C-WTP	6.9	1.2	N
12/02/2024	C-WTP	7	1.1	N
13/02/2024	C-WTP	7	1.2	N
14/02/2024	C-WTP	7	1.3	N
15/02/2024	C-WTP	7	1.4	N
16/02/2024	C-WTP	7	1.6	N
17/02/2024	C-WTP	6.9	1.6	N
18/02/2024	C-WTP	6.9	1.2	N
19/02/2024	C-WTP	6.9	1.5	N
20/02/2024	C-WTP	6.9	1.9	N
21/02/2024	C-WTP	6.7	2.5	N
22/02/2024	C-WTP	6.9	3.6	N
23/02/2024	C-WTP	6.9	2.4	N
24/02/2024	C-WTP	6.8	3.6	N
25/02/2024	C-WTP	6.8	7.8	N
26/02/2024	C-WTP	6.9	4.4	N
27/02/2024	C-WTP	6.9	1.5	N
28/02/2024	C-WTP	6.9	2.1	N
29/02/2024	C-WTP	6.8	0.3	N

Sydney Olympic Park- WTP Discharge Summary- February 2024

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	14	Not visible
8/02/2024	SOP-WTP	7.7	0.8	N
10/02/2024	SOP-WTP	7.8	0.04	N
11/02/2024	SOP-WTP	7.8	0.01	N
12/02/2024	SOP-WTP	7.8	0	N

14/02/2024	SOP-WTP	7.7	0.44	N
15/02/2024	SOP-WTP	7.8	0.03	N
16/02/2024	SOP-WTP	8.1	0	N
18/02/2024	SOP-WTP	7.9	0	N
19/02/2024	SOP-WTP	7.8	0.01	N
20/02/2024	SOP-WTP	7.9	0.9	N
21/02/2024	SOP-WTP	7.8	0.9	N
22/02/2024	SOP-WTP	7.7	1	N
23/02/2024	SOP-WTP	7.6	1.3	N
24/02/2024	SOP-WTP	7.5	0.2	N
25/02/2024	SOP-WTP	7.6	0.3	N
26/02/2024	SOP-WTP	7.6	0.07	N
28/02/2024	SOP-WTP	7.7	0.01	N