

The Bays- WTP Discharge Summary- October 2023

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units 6.5-8.5	NTU 18	Y/N Not visible
1/10/2023	C-WTP	11.2*	6.6	N
2/10/2023	C-WTP	11.5*	44.7*	N
3/10/2023	C-WTP	11.4*	404.1*	N
4/10/2023	C-WTP	11.6*	573*	N
5/10/2023	C-WTP	11.6*	58.1*	N
6/10/2023	C-WTP	11.5*	409.5*	N
7/10/2023	C-WTP	11.4*	1000*	N
8/10/2023	C-WTP	11.3*	1000*	N
9/10/2023	C-WTP	11.4*	531*	N
10/10/2023	C-WTP	10.6*	127*	N
11/10/2023	C-WTP	9.0*	38.3*	N
12/10/2023	C-WTP	7.7	4.7	N
13/10/2023	C-WTP	7.4	4.5	N
14/10/2023	C-WTP	7.4	5.3	N
15/10/2023	C-WTP	-	-	N
16/10/2023	C-WTP	7.4	2	N
17/10/2023	C-WTP	7.3	2.5	N
18/10/2023	C-WTP	7.4	2.1	N
19/10/2023	C-WTP	7.3	2	N
20/10/2023	C-WTP	7.2	2.1	N
21/10/2023	C-WTP	6.6	7.2	N
22/10/2023	C-WTP	7.1	4.6	N
23/10/2023	C-WTP	7.4	7.1	N
24/10/2023	C-WTP	7.3	4.6	N
25/10/2023	C-WTP	7.1	7.9	N
26/10/2023	C-WTP	7.1	9.1	N
27/10/2023	C-WTP	7	7.9	N
28/10/2023	C-WTP	6.5	11.4	N
29/10/2023	C-WTP	6.7	2.9	N
30/10/2023	C-WTP	7.1	2.6	N
31/10/2023	C-WTP	7.1	2.8	N

Note: AFJV suspects that the monitoring data marked with an * may be incorrect due to a potential error causing measurements to not reflect actual discharge quality, these values are being reviewed.

Sydney Olympic Park- WTP Discharge Summary-October 2023

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units 6.5-8.5	NTU 14	Y/N Not visible
1/10/2023	SOP-WTP	7.6	3.1	N
2/10/2023	SOP-WTP	7.6	3.1	N
3/10/2023	SOP-WTP	7.7	3	N
4/10/2023	SOP-WTP	7.8	2.9	N
5/10/2023	SOP-WTP	8	2.78	N
27/10/2023	SOP-WTP	7.5	3.3	N
28/10/2023	SOP-WTP	7.4	3.7	N
29/10/2023	SOP-WTP	7.3	3.7	N
30/10/2023	SOP-WTP	7.4	4.4	N
31/10/2023	SOP-WTP	7.4	5.3	N

Five Dock- WTP Discharge Summary-October 2023

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units 6.5-8.5	NTU 7	Y/N Not visible
1/10/2023	FDK-WTP	7.6	0.1	N
2/10/2023	FDK-WTP	7.6	0.1	N
3/10/2023	FDK-WTP	7.6	0.1	N
4/10/2023	FDK-WTP	7.5	0.1	N
5/10/2023	FDK-WTP	7.6	0.1	N
6/10/2023	FDK-WTP	7.7	0.2	N
7/10/2023	FDK-WTP	7.5	0.2	N
8/10/2023	FDK-WTP	7.6	0.2	N
9/10/2023	FDK-WTP	7.5	0.2	N
10/10/2023	FDK-WTP	7.5	0.1	N
11/10/2023	FDK-WTP	7.5	0.1	N
12/10/2023	FDK-WTP	7.6	0.1	N
13/10/2023	FDK-WTP	NA	NA	NA
14/10/2023	FDK-WTP	7.5	0.1	N
15/10/2023	FDK-WTP	7.5	0.1	N
16/10/2023	FDK-WTP	7.5	0.1	N
17/10/2023	FDK-WTP	7.6	0.2	N
18/10/2023	FDK-WTP	7.5	0.2	N
19/10/2023	FDK-WTP	7.6	0.2	N
20/10/2023	FDK-WTP	7.6	0.2	N
21/10/2023	FDK-WTP	7.6	0.2	N
22/10/2023	FDK-WTP	7.7	0.2	N
23/10/2023	FDK-WTP	7.5	0.1	N
24/10/2023	FDK-WTP	7.5	0.1	N
25/10/2023	FDK-WTP	7.5	0.1	N
26/10/2023	FDK-WTP	7.6	0.2	N
27/10/2023	FDK-WTP	7.6	0.2	N
28/10/2023	FDK-WTP	7.7	0.2	N
29/10/2023	FDK-WTP	7.7	0.2	N
30/10/2023	FDK-WTP	7.5	0.1	N
31/10/2023	FDK-WTP	7.5	0.1	N