

The Bays- WTP Discharge Summary- June 2024

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	18	Not visible
1/06/2024	C-WTP	7	0.6	N
2/06/2024	C-WTP	7	1.3	N
3/06/2024	C-WTP	7	0.2	N
4/06/2024	C-WTP	7	0.2	N
5/06/2024	C-WTP	6.9	0.3	N
6/06/2024	C-WTP	6.9	1	N
7/06/2024	C-WTP	7	0.4	N
8/06/2024	C-WTP	7	0.4	N
9/06/2024	C-WTP	7	0.5	N
10/06/2024	C-WTP	7	1.3	N
11/06/2024	C-WTP	7	1.4	N
12/06/2024	C-WTP	6.9	1	N
13/06/2024	C-WTP	7	0.2	N
14/06/2024	C-WTP	7	0.2	N
15/06/2024	C-WTP	7	0.3	N
16/06/2024	C-WTP	7	0.4	N
17/06/2024	C-WTP	7.1	0.2	N
18/06/2024	C-WTP	7.1	0.2	N
19/06/2024	C-WTP	7	0.9	N
20/06/2024	C-WTP	7	1.6	N
21/06/2024	C-WTP	7	1.3	N
22/06/2024	C-WTP	7	2.1	N
23/06/2024	C-WTP	7	2.9	N
24/06/2024	C-WTP	7.1	1.9	N
25/06/2024	C-WTP	7	1.7	N
26/06/2024	C-WTP	7.1	1.8	N
27/06/2024	C-WTP	7	0.6	N
28/06/2024	C-WTP	7	0.8	N
29/06/2024	C-WTP	6.9	1.4	N
30/06/2024	C-WTP	7.1	1	N

Sydney Olympic Park- WTP Discharge Summary-June- 2024

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	14	Not visible
1/06/2024	SOP-WTP	7.78	0.42	N
2/06/2024	SOP-WTP	7.91	0.4	N
3/06/2024	SOP-WTP	8.01	0.45	N
4/06/2024	SOP-WTP	8.07	0.41	N
5/06/2024	SOP-WTP	7.71	0.42	N

6/06/2024	SOP-WTP	7.97	0.42	N
7/06/2024	SOP-WTP	7.98	0.42	N
8/06/2024	SOP-WTP	7.83	0.44	N
9/06/2024	SOP-WTP	7.97	0.45	N
11/06/2024	SOP-WTP	8.05	0.45	N
12/06/2024	SOP-WTP	8.07	0.42	N
14/06/2024	SOP-WTP	8.03	0.83	N
15/06/2024	SOP-WTP	7.97	0.86	N
16/06/2024	SOP-WTP	7.93	0.87	N
17/06/2024	SOP-WTP	7.84	0.87	N
21/06/2024	SOP-WTP	7.74	0.86	N
22/06/2024	SOP-WTP	7.92	0.86	N
23/06/2024	SOP-WTP	7.9	0.86	N
24/06/2024	SOP-WTP	7.92	0.88	N
25/06/2024	SOP-WTP	7.94	0.86	N
26/06/2024	SOP-WTP	7.89	1.44	N
27/06/2024	SOP-WTP	7.98	0.87	N
28/06/2024	SOP-WTP	7.88	0.87	N
29/06/2024	SOP-WTP	7.65	0.87	N
30/06/2024	SOP-WTP	7.79	0.87	N