

## The Bays- WTP Discharge Summary - January 2025

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	18	Not visible
1/01/2025	C-WTP	7	1.4	N
2/01/2025	C-WTP	7	1.5	N
3/01/2025	C-WTP	7	1.6	N
4/01/2025	C-WTP	7	1.8	N
5/01/2025	C-WTP	7	2.5	N
6/01/2025	C-WTP	7	2.7	N
7/01/2025	C-WTP	7	1.4	N
8/01/2025	C-WTP	7	1.4	N
9/01/2025	C-WTP	7.2	1.6	N
10/01/2025	C-WTP	7	1.6	N
11/01/2025	C-WTP	7	1.6	N
12/01/2025	C-WTP	6.9	1.6	N
13/01/2025	C-WTP	7	2.2	N
14/01/2025	C-WTP	7.1	1.9	N
15/01/2025	C-WTP	6.9	1.7	N
16/01/2025	C-WTP	7	1.8	N
17/01/2025	C-WTP	7.1	1.8	N
18/01/2025	C-WTP	7	1.8	N
19/01/2025	C-WTP	7	1.8	N
20/01/2025	C-WTP	7	1.7	N
21/01/2025	C-WTP	7.3	1.7	N
22/01/2025	C-WTP	7	1.7	N
23/01/2025	C-WTP	7.1	1.7	N
24/01/2025	C-WTP	7	1.7	N
25/01/2025	C-WTP	6.9	1.8	N
26/01/2025	C-WTP	7	2	N
27/01/2025	C-WTP	7	2.3	N
28/01/2025	C-WTP	7	2	N
29/01/2025	C-WTP	7.1	1.8	N
30/01/2025	C-WTP	7.1	1.7	N
31/01/2025	C-WTP	6.9	1.7	N

### Burwood- WTP Discharge Summary- January 2025

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	23	Not visible
20/01/2025	BWD-WTP	6.7	0.1	N
21/01/2025	BWD-WTP	6.6	0.1	N
23/01/2025	BWD-WTP	6.6	0.9	N
28/01/2025	BWD-WTP	6.8	0.3	N
30/01/2025	BWD-WTP	7	1.2	N
31/01/2025	BWD-WTP	6.9	1.3	N