

The Bays- WTP Discharge Summary- August 2023

| Discharge Date | Site/WTP | pH units | NTU | Oil and Grease |
|----------------|----------|----------|---------------------|----------------|
| | | Probe | Probe (correlation) | Visual |
| | | pH units | NTU | Y/N |
| | | 6.5-8.5 | 18 | Not visible |
| 1/08/2023 | C-WTP | 7 | 0.2 | N |
| 2/08/2023 | C-WTP | 7.3 | 0.2 | N |
| 3/08/2023 | C-WTP | 7.3 | 0.2 | N |
| 4/08/2023 | C-WTP | 7.5 | 0.2 | N |
| 5/08/2023 | C-WTP | 7.5 | 0.2 | N |
| 6/08/2023 | C-WTP | 7.6 | 0.2 | N |
| 7/08/2023 | C-WTP | 8.1 | 0.2 | N |
| 8/08/2023 | C-WTP | 8.3 | 0.2 | N |
| 9/08/2023 | C-WTP | 7.6 | 0.2 | N |
| 10/08/2023 | C-WTP | 7 | 0.2 | N |
| 11/08/2023 | C-WTP | 7 | 0.2 | N |
| 12/08/2023 | C-WTP | 7 | 0.2 | N |
| 13/08/2023 | C-WTP | 7 | 0.2 | N |
| 14/08/2023 | C-WTP | 7 | 0.2 | N |
| 15/08/2023 | C-WTP | 7 | 0.2 | N |
| 16/08/2023 | C-WTP | 7 | 0.2 | N |
| 17/08/2023 | C-WTP | 7.5 | 0.2 | N |
| 18/08/2023 | C-WTP | 7.8 | 0.2 | N |
| 19/08/2023 | C-WTP | 7.8 | 0.2 | N |
| 20/08/2023 | C-WTP | 7.7 | 0.2 | N |
| 21/08/2023 | C-WTP | 7.7 | 0.2 | N |
| 22/08/2023 | C-WTP | 8.5 | 0.2 | N |
| 23/08/2023 | C-WTP | 7.6 | 2.8 | N |
| 24/08/2023 | C-WTP | 7.3 | 7.8 | N |
| 25/08/2023 | C-WTP | 7.6 | 5.2 | N |
| 26/08/2023 | C-WTP | 8.3 | 6.3 | N |
| 27/08/2023 | C-WTP | 8.3 | 6.3 | N |
| 28/08/2023 | C-WTP | 7.9 | 3.4 | N |
| 29/08/2023 | C-WTP | 7.5 | 0.9 | N |
| 30/08/2023 | C-WTP | 7.8 | 2.1 | N |
| 31/08/2023 | C-WTP | 8 | 4.9 | N |

Sydney Olympic Park- WTP Discharge Summary-August 2023

| Discharge Date | Site/WTP | pH units | NTU | Oil and Grease |
|----------------|----------|----------|---------------------|----------------|
| | | Probe | Probe (correlation) | Visual |
| | | pH units | NTU | Y/N |
| | | 6.5-8.5 | 14 | Not visible |
| 1/08/2023 | SOP-WTP | 7.8 | 2.8 | N |
| 2/08/2023 | SOP-WTP | 7.9 | 2.7 | N |
| 3/08/2023 | SOP-WTP | 7.9 | 3.4 | N |
| 4/08/2023 | SOP-WTP | 7.9 | 3.4 | N |

| | | | | |
|------------|---------|-----|-----|---|
| 5/08/2023 | SOP-WTP | 7.9 | 3.4 | N |
| 6/08/2023 | SOP-WTP | 7.9 | 3.5 | N |
| 7/08/2023 | SOP-WTP | 7.8 | 3.5 | N |
| 8/08/2023 | SOP-WTP | 7.6 | 3.6 | N |
| 9/08/2023 | SOP-WTP | 7.6 | 3.6 | N |
| 10/08/2023 | SOP-WTP | 7.6 | 3.6 | N |
| 11/08/2023 | SOP-WTP | 7.7 | 3.6 | N |
| 12/08/2023 | SOP-WTP | 7.7 | 3.7 | N |
| 13/08/2023 | SOP-WTP | 7.8 | 3.8 | N |
| 14/08/2023 | SOP-WTP | 7.6 | 3.9 | N |
| 15/08/2023 | SOP-WTP | 7.5 | 4 | N |
| 17/08/2023 | SOP-WTP | 7.3 | 4.1 | N |
| 23/08/2023 | SOP-WTP | 7.4 | 2 | N |
| 24/08/2023 | SOP-WTP | 7.2 | 2.4 | N |
| 25/08/2023 | SOP-WTP | 7.2 | 2 | N |
| 26/08/2023 | SOP-WTP | 7.1 | 2.1 | N |
| 27/08/2023 | SOP-WTP | 7.3 | 2.2 | N |
| 29/08/2023 | SOP-WTP | 7.6 | 1.9 | N |
| 30/08/2023 | SOP-WTP | 7.4 | 1.9 | N |
| 31/08/2023 | SOP-WTP | 7.2 | 1.9 | N |

Five Dock- WTP Discharge Summary-August 2023

| Discharge Date | Site/WTP | pH units | NTU | Oil and Grease |
|----------------|----------|----------|---------------------|----------------|
| | | Probe | Probe (correlation) | Visual |
| | | pH units | NTU | Y/N |
| | | 6.5-8.5 | 7 | Not visible |
| 1/08/2023 | FDK-WTP | 7.3 | 0.2 | N |
| 2/08/2023 | FDK-WTP | 7.3 | 0.2 | N |
| 3/08/2023 | FDK-WTP | 7.3 | 0.2 | N |
| 4/08/2023 | FDK-WTP | 7.1 | 0.1 | N |
| 5/08/2023 | FDK-WTP | 7.3 | 0.1 | N |
| 6/08/2023 | FDK-WTP | 7.1 | 0.2 | N |
| 7/08/2023 | FDK-WTP | 7.1 | 0.2 | N |
| 8/08/2023 | FDK-WTP | 7.3 | 0.2 | N |
| 9/08/2023 | FDK-WTP | 7.2 | 0.2 | N |
| 10/08/2023 | FDK-WTP | 7.2 | 0.2 | N |
| 11/08/2023 | FDK-WTP | 7.3 | 0.2 | N |
| 12/08/2023 | FDK-WTP | 7.4 | 0.2 | N |
| 13/08/2023 | FDK-WTP | 7.5 | 0.2 | N |
| 14/08/2023 | FDK-WTP | 7.3 | 0.2 | N |
| 15/08/2023 | FDK-WTP | 7.2 | 0.2 | N |
| 16/08/2023 | FDK-WTP | 7.4 | 0.2 | N |
| 17/08/2023 | FDK-WTP | 7.3 | 0.2 | N |
| 18/08/2023 | FDK-WTP | 7.4 | 0.2 | N |
| 19/08/2023 | FDK-WTP | 7.7 | 0.2 | N |
| 20/08/2023 | FDK-WTP | 7.7 | 0.2 | N |
| 21/08/2023 | FDK-WTP | 7.4 | 0.1 | N |

| | | | | |
|------------|---------|-----|-----|---|
| 22/08/2023 | FDK-WTP | 7.4 | 0.1 | N |
| 23/08/2023 | FDK-WTP | 7.5 | 0.2 | N |
| 24/08/2023 | FDK-WTP | 7.5 | 0.2 | N |
| 25/08/2023 | FDK-WTP | 7.5 | 0.2 | N |
| 26/08/2023 | FDK-WTP | 7.6 | 0.2 | N |
| 27/08/2023 | FDK-WTP | 7.6 | 0.2 | N |
| 28/08/2023 | FDK-WTP | 7.5 | 0.2 | N |
| 29/08/2023 | FDK-WTP | 7.7 | 0.1 | N |
| 30/08/2023 | FDK-WTP | 7.7 | 0.2 | N |
| 31/08/2023 | FDK-WTP | 7.4 | 0.1 | N |