

The Bays- WTP Sampling and Discharge Summary- July

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	18	Not visible
1/07/2023	C-WTP	7	0.2	N
2/07/2023	C-WTP	7	0.2	N
3/07/2023	C-WTP	7.4	0.2	N
4/07/2023	C-WTP	7.7	0.2	N
5/07/2023	C-WTP	7	0.2	N
6/07/2023	C-WTP	7	0.2	N
7/07/2023	C-WTP	7	0.2	N
8/07/2023	C-WTP	7.4	0.2	N
9/07/2023	C-WTP	7.4	0.2	N
10/07/2023	C-WTP	9.2	11	N
11/07/2023	C-WTP	7	0.2	N
12/07/2023	C-WTP	7.2	0.2	N
13/07/2023	C-WTP	7.5	0.2	N
14/07/2023	C-WTP	7.5	0.2	N
15/07/2023	C-WTP	7.3	0.2	N
16/07/2023	C-WTP	7	0.2	N
17/07/2023	C-WTP	7	0.2	N
18/07/2023	C-WTP	7	0.2	N
19/07/2023	C-WTP	7	0.2	N
20/07/2023	C-WTP	7	0.2	N
21/07/2023	C-WTP	7	0.2	N
22/07/2023	C-WTP	7	0.2	N
23/07/2023	C-WTP	7	0.2	N
24/07/2023	C-WTP	7	0.2	N
25/07/2023	C-WTP	7	0.2	N
26/07/2023	C-WTP	8.9	1.6	N
27/07/2023	C-WTP	7	0.2	N
28/07/2023	C-WTP	7	0.2	N
29/07/2023	C-WTP	7	0.2	N
30/07/2023	C-WTP	7	0.2	N
31/07/2023	C-WTP	7	0.2	N

Sydney Olympic Park- WTP Sampling and Discharge Summary- July

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	14	Not visible
2/07/2023	SOP-WTP	7.96	2	N
3/07/2023	SOP-WTP	7.96	2.1	N
4/07/2023	SOP-WTP	7.94	2.3	N
5/07/2023	SOP-WTP	8	2.4	N
6/07/2023	SOP-WTP	7.98	2.6	N
7/07/2023	SOP-WTP	7.97	2.5	N
8/07/2023	SOP-WTP	7.91	2.5	N
9/07/2023	SOP-WTP	8	2.6	N
10/07/2023	SOP-WTP	8	2.6	N
11/07/2023	SOP-WTP	7.88	2.7	N
12/07/2023	SOP-WTP	7.93	2.8	N
13/07/2023	SOP-WTP	7.98	2.8	N
14/07/2023	SOP-WTP	8	2.8	N
15/07/2023	SOP-WTP	8	2.8	N
16/07/2023	SOP-WTP	7.9	2.9	N
17/07/2023	SOP-WTP	7.84	2.6	N
18/07/2023	SOP-WTP	7.9	2.5	N
20/07/2023	SOP-WTP	7.95	2.5	N
26/07/2023	SOP-WTP	7.74	3.1	N
27/07/2023	SOP-WTP	7.76	3.2	N
28/07/2023	SOP-WTP	7.77	3.3	N
29/07/2023	SOP-WTP	7.78	3.3	N
30/07/2023	SOP-WTP	7.87	3.2	N

Five Dock- WTP Sampling and Discharge Summary- July

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	7	Not visible
1/07/2023	FDK-WTP	7.0	0.2	N
2/07/2023	FDK-WTP	7.0	0.2	N
3/07/2023	FDK-WTP	6.8	0.2	N
4/07/2023	FDK-WTP	6.8	0.2	N

5/07/2023	FDK-WTP	6.9	2.9	N
6/07/2023	FDK-WTP	6.9	1.7	N
7/07/2023	FDK-WTP	7.0	0.9	N
8/07/2023	FDK-WTP	7.0	0.2	N
9/07/2023	FDK-WTP	7.2	0.2	N
10/07/2023	FDK-WTP	6.8	0.7	N
11/07/2023	FDK-WTP	6.9	0.2	N
12/07/2023	FDK-WTP	6.8	0.2	N
13/07/2023	FDK-WTP	6.3	0.2	N
14/07/2023	FDK-WTP	6.3	0.1	N
15/07/2023	FDK-WTP	6.4	0.1	N
16/07/2023	FDK-WTP	7.0	0.2	N
17/07/2023	FDK-WTP	6.6	0.2	N
18/07/2023	FDK-WTP	6.8	0.2	N
19/07/2023	FDK-WTP	6.7	1.7	N
20/07/2023	FDK-WTP	6.7	0.2	N
21/07/2023	FDK-WTP	6.8	0.2	N
22/07/2023	FDK-WTP	6.6	0.2	N
23/07/2023	FDK-WTP	6.9	5.4	N
24/07/2023	FDK-WTP	6.9	6.3	N
25/07/2023	FDK-WTP	6.9	0.2	N
26/07/2023	FDK-WTP	6.7	0.2	N
27/07/2023	FDK-WTP	7.2	0.2	N
28/07/2023	FDK-WTP	7.3	0.2	N
29/07/2023	FDK-WTP	8.4	9	N
30/07/2023	FDK-WTP	7.2	0.2	N

Pre-cast Yard Sampling and Discharge Summary- July

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	50	Not visible
3/07/2023	PCY	8.2	27.4	N