

The Bays- WTP Sampling and Discharge Summary- June

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	18	Not visible
1/06/2023	C-WTP	7.8	0.2	N
2/06/2023	C-WTP	8	14	N
3/06/2023	C-WTP	7.9	0.1	N
4/06/2023	C-WTP	8	0.1	N
5/06/2023	C-WTP	7.9	0.2	N
6/06/2023	C-WTP	7.7	0.1	N
7/06/2023	C-WTP	7.2	0.2	N
8/06/2023	C-WTP	7.4	0.2	N
9/06/2023	C-WTP	7.3	0.2	N
10/06/2023	C-WTP	7.3	0.1	N
11/06/2023	C-WTP	7.3	0.1	N
12/06/2023	C-WTP	7.7	0.2	N
13/06/2023	C-WTP	7.2	0.2	N
14/06/2023	C-WTP	6.8	0.1	N
15/06/2023	C-WTP	6.5	0.2	N
16/06/2023	C-WTP	6.7	0.2	N
17/06/2023	C-WTP	6.7	0.2	N
18/06/2023	C-WTP	6.6	0.1	N
19/06/2023	C-WTP	7	0.1	N
20/06/2023	C-WTP	7.2	0.1	N
21/06/2023	C-WTP	8	0.2	N
22/06/2023	C-WTP	7.4	0.2	N
23/06/2023	C-WTP	7.3	0.2	N
24/06/2023	C-WTP	6.9	0.2	N
25/06/2023	C-WTP	7.6	0.2	N
26/06/2023	C-WTP	7.6	0.2	N
27/06/2023	C-WTP	7.3	0.2	N
28/06/2023	C-WTP	7.9	0.2	N
29/06/2023	C-WTP	6.8	0.2	N
30/06/2023	C-WTP	7	0.2	N

Sydney Olympic Park- WTP Sampling and Discharge Summary- June

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	14	Not visible
8/06/2023	SOP-WTP			
19/06/2023	SOP-WTP	7.55	1.9	N
20/06/2023	SOP-WTP	7.61	2	N
21/06/2023	SOP-WTP	7.76	2	N
22/06/2023	SOP-WTP	7.8	2.1	N
23/06/2023	SOP-WTP	7.98	2	N
29/06/2023	SOP-WTP	7.95	1.9	N
30/06/2023	SOP-WTP	7.94	2	N

Burwood- WTP Sampling and Discharge Summary- June

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	18	Not visible
1/06/2023	BWD-WTP	7.4	5	N
22/06/2023	BWD-WTP	7.2	5	N

Five Dock- WTP Sampling and Discharge Summary- June

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	18	Not visible
3/06/2023	FDK-WTP	6.5	0.2	N
4/06/2023	FDK-WTP	6.6	0.2	N
5/06/2023	FDK-WTP	6.6	0.2	N
7/06/2023	FDK-WTP	6.6	0.2	N
8/06/2023	FDK-WTP	6.7	0.3	N
9/06/2023	FDK-WTP	6.9	0.2	N
11/06/2023	FDK-WTP	7.7	0.2	N
12/06/2023	FDK-WTP	6.8	0.3	N
13/06/2023	FDK-WTP	6.4	0.3	N
14/06/2023	FDK-WTP	7.0	0.2	N

15/06/2023	FDK-WTP	6.5	1	N
16/06/2023	FDK-WTP	6.8	2.2	N
17/06/2023	FDK-WTP	7.1	2.9	N
18/06/2023	FDK-WTP	7.5	3.4	N
19/06/2023	FDK-WTP	6.8	4.7	N
20/06/2023	FDK-WTP	6.8	1	N
21/06/2023	FDK-WTP	6.9	2.2	N
24/06/2023	FDK-WTP	6.8	3.9	N
26/06/2023	FDK-WTP	6.9	6.5	N
28/06/2023	FDK-WTP	6.8	8.5	N
29/06/2023	FDK-WTP	6.7	10	N
30/06/2023	BWD-WTP	6.8	0.2	N

Pre-cast Yard Sampling and Discharge Summary- June

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	50	Not visible
5/06/2023	PCY	7.1	29.4	N