

The Bays- WTP Discharge Summary- July 2024

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	18	Not visible
1/07/2024	C-WTP	7.1	1.2	N
2/07/2024	C-WTP	7.1	0.9	N
3/07/2024	C-WTP	7.1	0.3	N
4/07/2024	C-WTP	7	0.7	N
5/07/2024	C-WTP	6.9	3.3	N
6/07/2024	C-WTP	6.9	1.2	N
7/07/2024	C-WTP	6.9	1	N
8/07/2024	C-WTP	7	1.6	N
9/07/2024	C-WTP	7.1	2.3	N
10/07/2024	C-WTP	6.9	0.7	N
11/07/2024	C-WTP	6.9	0.7	N
12/07/2024	C-WTP	7	1	N
13/07/2024	C-WTP	7	0.6	N
14/07/2024	C-WTP	7	1.2	N
15/07/2024	C-WTP	7	1.3	N
16/07/2024	C-WTP	7	0.8	N
17/07/2024	C-WTP	7	0.2	N
18/07/2024	C-WTP	6.9	0.7	N
19/07/2024	C-WTP	6.8	0.6	N
20/07/2024	C-WTP	7	0.4	N
21/07/2024	C-WTP	7	0.4	N
22/07/2024	C-WTP	7.1	0.2	N
23/07/2024	C-WTP	7	0.2	N
24/07/2024	C-WTP	7	0.3	N
25/07/2024	C-WTP	7	0.3	N
26/07/2024	C-WTP	7	0.5	N
27/07/2024	C-WTP	7	0.5	N
28/07/2024	C-WTP	6.9	0.3	N
29/07/2024	C-WTP	7	0.6	N
30/07/2024	C-WTP	7	0.5	N
31/07/2024	C-WTP	7	0.7	N

Sydney Olympic Park- WTP Discharge Summary-July- 2024

Discharge Date	Site/WTP	pH units	NTU	Oil and Grease
		Probe	Probe (correlation)	Visual
		pH units	NTU	Y/N
		6.5-8.5	14	Not visible
1/07/2024	SOP-WTP	7.9	0.87	N
2/07/2024	SOP-WTP	7.85	0.87	N
3/07/2024	SOP-WTP	7.43	0.9	N
4/07/2024	SOP-WTP	7.87	0.87	N

5/07/2024	SOP-WTP	8.06	0.87	N
6/07/2024	SOP-WTP	8.2	0.9	N
7/07/2024	SOP-WTP	8.06	0.94	N
8/07/2024	SOP-WTP	8.05	0.91	N
10/07/2024	SOP-WTP	7.69	0.98	N
11/07/2024	SOP-WTP	7.53	1.08	N
12/07/2024	SOP-WTP	7.53	1.09	N
15/07/2024	SOP-WTP	7.54	1.09	N
16/07/2024	SOP-WTP	7.57	1.07	N

Note: The Sydney Olympic Park water treatment plant has been decommissioned, and no further discharges will occur.