

The Bays WTP Sampling and Discharge Summary

Discharge Date		Turbidity/TSS	Oil and Grease
	Probe	Probe (correlation)	Visual
	pH units	NTU	Y/N
	6.5-8.5	18	Not visible
1/10/2024	7.1	2.9	N
2/10/2024	6.9	2.4	N
3/10/2024	7	2.3	N
4/10/2024	7	2.5	N
5/10/2024	6.9	1.5	N
6/10/2024	6.9	1.5	N
7/10/2024	6.9	1.5	N
8/10/2024	7	1.2	N
9/10/2024	7	2.6	N
10/10/2024	7	1.3	N
11/10/2024	7	2.4	N
12/10/2024	7	1.2	N
13/10/2024	7	1.5	N
14/10/2024	7	1.2	N
15/10/2024	6.9	0.7	N
16/10/2024	6.9	0.6	N
17/10/2024	6.9	0.7	N
18/10/2024	7	0.4	N
19/10/2024	7	0.8	N
20/10/2024	7	0.4	N
21/10/2024	7	0.6	N
22/10/2024	6.9	0.7	N
23/10/2024	6.9	1.4	N
24/10/2024	6.9	1	N
25/10/2024	6.9	2	N
26/10/2024	6.9	2	N
27/10/2024	6.9	1.6	N
28/10/2024	6.9	1.2	N
29/10/2024	6.9	0.8	N
30/10/2024	6.9	0.6	N
31/10/2024	6.9	0.8	N

C-WTP

Point 4